


**2.5 U-Value thermal performance of the door ( $U_w$ ) in accordance with EN ISO 10077-1:2006 is:**

**0.94 W/m<sup>2</sup>K**

All profile and PSI calculations are in accordance with BS EN ISO 10077-2:2003

### **3 Authorisation**

|                   |  |
|-------------------|--|
|                   | <b>Issued by:</b>  |
| <b>Signature:</b> |  |
| <b>Name:</b>      | Michael Handley  |
| <b>Title:</b>     | Senior Engineer  |

*The legal validity of this report can only be claimed on presentation of the complete report and electronic information if applicable.*